

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE N/A	PAGE 1 OF 7
2. AMENDMENT/MODIFICATION NO. 0008	3. EFFECTIVE DATE JUL. 26, 2002	4. REQUISITION/PURCHASE REQ. NO. N/A	5. PROJECT NO. (If applicable) SPEC. NO. 1266	
6. ISSUED BY CODE		7. ADMINISTERED BY (If other than Item 6) CODE		
DEPARTMENT OF THE ARMY U.S. ARMY ENGINEER DISTRICT, LOS ANGELES LOS ANGELES, CALIFORNIA 90053-2325		DISTRICT ENGINEER U.S. ARMY ENGINEER DISTRICT, LOS ANGELES 911 WILSHIRE BLVD LOS ANGELES, CALIFORNIA 90053-2325		

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(√)	9A. AMENDMENT OF SOLICITATION NO. DACA05-02-B-0002
	×	9B. DATED (SEE ITEM 11) N/A
		10A. MODIFICATION OF CONTRACTS/ORDER NO. N/A
		10B. DATED (SEE ITEM 13) N/A
CODE	FACILITY CODE	

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

N/A

NOTE: ITEM 13 BELOW IS N/A.

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

(√)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. N/A
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority) N/A

**E. IMPORTANT:** Contractor ☐ is not, ☐ is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

557th DS Maintenance Shop

Fort Irwin, CA

**NOTE: The Bid Opening has been changed to August 08, 2002.**

2 Encl.

1. Revised Pages: Front End (Page 1,2, 8), 02300-8

1. Revised Drawings: S0.01, S5.02

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		BY (Signature of Contracting Officer)	

<b>SOLICITATION, OFFER, AND AWARD</b> <i>(Construction, Alteration, or Repair)</i>	1. SOLICITATION NO. DACA05-02-B-0002	2. TYPE OF SOLICITATION <input checked="checked" type="checkbox"/> SEALED BID (IFB) <input type="checkbox"/> NEGOTIATED (RFP)	3. DATE ISSUED 18-Jun-2002	PAGE OF PAGES 1 OF 186
<b>IMPORTANT - The "offer" section on the reverse must be fully completed by offeror.</b>				
4. CONTRACT NO.	5. REQUISITION/PURCHASE REQUEST NO. W62N6M-2122-5933		6. PROJECT NO.	
7. ISSUED BY DEPARTMENT OF THE ARMY CORPS OF ENGINEERS, SACRAMENTO 1325 J STREET SACRAMENTO CA 95814-2922  TEL: (916) 557-5238      FAX: (916) 557-7842		DACA05	8. ADDRESS OFFER TO <i>(If Other Than Item 7)</i> DEPARTMENT OF THE ARMY CORPS OF ENGINEERS, LOS ANGELES ATTN: CONTRACTING DIVISION P.O. BOX 532711 LOS ANGELES, CA 90053-2325  TEL:      FAX:	
9. FOR INFORMATION CALL:	A. NAME MS. CHERYL GANNAWAY		B. TELEPHONE NO. <i>(Include area code)</i> <i>(NO COLLECT CALLS)</i> 916.557.6933	
<b>SOLICITATION</b>				
<b>NOTE: In sealed bid solicitations "offer" and "offeror" mean "bid" and "bidder".</b>				
10. THE GOVERNMENT REQUIRES PERFORMANCE OF THE WORK DESCRIBED IN THESE DOCUMENTS <i>(Title, identifying no., date):</i>  557th DS Maintenance Shop @ Fort Irwin, California Spec. No. 1266  Description: Construct a Direct Support (DS) Vehicle Maintenance Facility, consisting of hardstand parking of approximately 1,400,000 SF, Vehicle Maintenance Shop of approx. 59,000 SF, and elevator and a two-bay wash facility outside of the facility. Also, included is an approx. 900 SF Development Storage Facility. Supporting facilities shall include utilities; electrical services; fire protection and alarm systems; paving; sidewalks; curbs and gutters; parking; security fence and lighting; information systems; and site improvements.  ANY CONTRACT AWARDED UNDER THIS SOLICITATION WILL BE MADE PURSUANT TO PUBLIC LAW 100-656, SMALL BUSINESS COMPETITIVENESS DEMONSTRATION PROGRAM.  Estimated Cost Range: \$10,000,000.00 to \$25,000,000.00				
11. The Contractor shall begin performance within <u>10</u> calendar days and complete it within <u>365</u> calendar days after receiving <input type="checkbox"/> award, <input checked="checked" type="checkbox"/> notice to proceed. This performance period is <input checked="checked" type="checkbox"/> mandatory, <input type="checkbox"/> negotiable. <i>(See FAR 52.211-10 .)</i>				
12 A. THE CONTRACTOR MUST FURNISH ANY REQUIRED PERFORMANCE AND PAYMENT <i>(If "YES," indicate within how many calendar days after award in Item 12B.)</i> <input checked="checked" type="checkbox"/> YES <input type="checkbox"/> NO			12B. CALENDAR DAYS  10	
13. ADDITIONAL SOLICITATION REQUIREMENTS: A. Sealed offers in original and <u>0</u> copies to perform the work required are due at the place specified in Item 8 by <u>13:00:00</u> <i>(hour)</i> local time <u>8/08/02</u> <i>(date)</i> . If this is a sealed bid solicitation, offers must be publicly opened at that time. Sealed envelopes containing offers shall be marked to show the offeror's name and address, the solicitation number, and the date and time offers are due. B. An offer guarantee <input checked="checked" type="checkbox"/> is, <input type="checkbox"/> is not required. C. All offers are subject to the (1) work requirements, and (2) other provisions and clauses incorporated in the solicitation in full text or by reference. D. Offers providing less than <u>60</u> calendar days for Government acceptance after the date offers are due will not be considered and will be rejected.				

<b>SOLICITATION, OFFER, AND AWARD</b> <i>(Construction, Alteration, or Repair)</i>		1. SOLICITATION NO. DACA05-02-B-0002	2. TYPE OF SOLICITATION <input checked="" type="checkbox"/> SEALED BID (IFB) <input type="checkbox"/> NEGOTIATED (RFP)	3. DATE ISSUED 18-Jun-2002	DACA05-02-B-0002 PAGE OF PAGES 1 OF 186
<b>IMPORTANT - The "offer" section on the reverse must be fully completed by offeror.</b>					
4. CONTRACT NO.		5. REQUISITION/PURCHASE REQUEST NO. W62N6M-2122-5933		6. PROJECT NO.	
7. ISSUED BY DEPARTMENT OF THE ARMY CORPS OF ENGINEERS, SACRAMENTO 1325 J STREET SACRAMENTO CA 95814-2922  TEL: (916) 557-5238      FAX: (916) 557-7842		CODE DACA05	8. ADDRESS OFFER TO <i>(If Other Than Item 7)</i> DEPARTMENT OF THE ARMY CORPS OF ENGINEERS, LOS ANGELES ATTN: CONTRACTING DIVISION P.O. BOX 532711 LOS ANGELES, CA 90053-2325  TEL:      FAX:		
9. FOR INFORMATION CALL:		A. NAME MS. CHERYL GANNAWAY		B. TELEPHONE NO. <i>(Include area code)</i> <i>(NO COLLECT CALLS)</i> 916.557.6933	
<b>SOLICITATION</b>					
<b>NOTE: In sealed bid solicitations "offer" and "offeror" mean "bid" and "bidder".</b>					
10. THE GOVERNMENT REQUIRES PERFORMANCE OF THE WORK DESCRIBED IN THESE DOCUMENTS <i>(Title, identifying no., date):</i>  557th DS Maintenance Shop @ Fort Irwin, California Spec. No. 1266  Description: Construct a Direct Support (DS) Vehicle Maintenance Facility, consisting of hardstand parking of approximately 1,400,000 SF, Vehicle Maintenance Shop of approx. 59,000 SF, and elevator and a two-bay wash facility outside of the facility. Also, included is an approx. 900 SF Development Storage Facility. Supporting facilities shall include utilities; electrical services; fire protection and alarm systems; paving; sidewalks; curbs and gutters; parking; security fence and lighting; information systems; and site improvements.  ANY CONTRACT AWARDED UNDER THIS SOLICITATION WILL BE MADE PURSUANT TO PUBLIC LAW 100-656, SMALL BUSINESS COMPETITIVENESS DEMONSTRATION PROGRAM.  Estimated Cost Range: \$10,000,000.00 to \$25,000,000.00					
11. The Contractor shall begin performance within <u>10</u> calendar days and complete it within <u>365</u> calendar days after receiving <input type="checkbox"/> award, <input checked="" type="checkbox"/> notice to proceed. This performance period is <input checked="" type="checkbox"/> mandatory, <input type="checkbox"/> negotiable. <i>(See FAR 52.211-10 .)</i>					
12 A. THE CONTRACTOR MUST FURNISH ANY REQUIRED PERFORMANCE AND PAYMENT <i>(If "YES," indicate within how many calendar days after award in Item 12B.)</i> <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO				12B. CALENDAR DAYS  10	
13. ADDITIONAL SOLICITATION REQUIREMENTS: A. Sealed offers in original and <u>0</u> copies to perform the work required are due at the place specified in Item 8 by <u>13:00:00</u> (hour) local time <u>8/08/02</u> (date). If this is a sealed bid solicitation, offers must be publicly opened at that time. Sealed envelopes containing offers shall be marked to show the offeror's name and address, the solicitation number, and the date and time offers are due. B. An offer guarantee <input checked="" type="checkbox"/> is, <input type="checkbox"/> is not required. C. All offers are subject to the (1) work requirements, and (2) other provisions and clauses incorporated in the solicitation in full text or by reference. D. Offers providing less than <u>60</u> calendar days for Government acceptance after the date offers are due will not be considered and will be rejected.					

52.0214-5001 DIRECTIONS FOR SUBMITTING BIDS (APR 2002)

Envelopes containing bids must be sealed, marked and addressed as follows:

MARK ENVELOPES:

Bid under IFB No. DACA05-02-B-0002  
***Bid Opening Date: August 08, 2002***

ADDRESS ENVELOPES TO:

Department of the Army  
U. S. Army Engineer District, Los Angeles  
ATTN: Contracting Division  
C/O: Ms. Lucia Carvajal  
P. O. Box 532711  
Los Angeles, CA 90053-2325

SPECIAL INSTRUCTIONS PERTAINING TO HAND-CARRIED BIDS:

Due to security precautions, all Corps of Engineers visitors/couriers are now required to check in at the Public Affairs Office (PAO), Suite 980, 911 Wilshire Blvd, Los Angeles, CA. Bidders are no longer permitted to hand-carry their bids directly to Contracting Division without an authorized escort. Bids may NOT be left unattended at the Public Affairs Office (PAO), Suite 980.

Bidders who desire to hand-deliver their bids prior to the scheduled bid opening time/date must notify the Contracting Division to arrange for receipt of their bid by Contracting Division personnel. Normally the contact will be the Contract Specialist designated above. In the event the Contract Specialist cannot be reached, please call the main Contracting Division telephone number, 213-452-3231 or the following alternative telephone numbers -3233, -3245, -3234, or -3235, in order to request assistance.

30 minutes prior to the scheduled bid opening time/date, the Bid Opening Officer will be in the Public Affairs Office (PAO) Suite 980, to accept bids. After visitor in-processing, all bidders will subsequently be escorted to Bid Opening Room, where the bids will be publicly opened and read.

In order to expedite visitor processing, bidders are encouraged to complete the information requested on the Notice of Visitor(s) Form (attached). The completed form can be faxed to the Contract Specialist at (213)452-4184 or 4187, prior to the date for receipt of bids. In addition, no more than 2 visitors per firm will be permitted within the building. No exceptions will be made. The offeror is responsible for compliance with the security requirements and shall ensure that any company representative, courier or delivery personnel are aware of these special procedures pertaining to hand carried bids.

### 3.2 DITCHES, GUTTERS, AND CHANNEL CHANGES

Ditches, gutters, and channel changes shall be cut accurately to the cross sections and grades indicated. All roots, stumps, rock, and foreign matter in the sides and bottom of ditches, gutters, and channel changes shall be trimmed and dressed or removed to conform to the slope, grade, and shape of the section indicated. Care shall be taken not to excavate ditches and gutters below the grades indicated. Excessive ditch and gutter excavation shall be backfilled to grade either with satisfactory, thoroughly compacted material or with suitable stone or cobble to form an adequate gutter paving as directed. All ditches and gutters excavated under this section shall be maintained until final acceptance of the work. Satisfactory material excavated from ditches and channel changes may be placed in fill areas. Unsatisfactory and excess excavated material shall be disposed of in accordance with directions in paragraph EXCAVATION. No excavated material shall be deposited closer to the edges of the ditches than indicated and in no case less than 3 feet.

### 3.3 BACKFILL ADJACENT TO STRUCTURES

Backfill adjacent to structures shall be placed and compacted uniformly in such manner as to prevent wedging action or eccentric loading upon or against the structures. Slopes bounding or within areas to be backfilled shall be stepped or serrated to prevent sliding of the fill. During backfilling operations and in the formation of embankments, equipment that will overload the structure in passing over and compacting these fills shall not be used. Backfill for storm drains and subdrains, including the bedding and backfill for structures other than culverts and drains, shall conform to the additional requirements in other applicable sections.

### 3.4 PREPARATION OF GROUND SURFACE FOR FILL

All vegetation, such as roots, brush, grass, and all decayed vegetable matter, rubbish, and other unsatisfactory material within the area upon which fill is to be placed, shall be stripped and removed. Following stripping, the ground surface on which fill will be placed shall be plowed and disked to a minimum depth of **6 inches** clay balls and cemented clods shall be pulverized; the soil moistened or aerated, as necessary, and thoroughly mixed. The scarified layer shall then be compacted to at least 95 percent degree of compaction. Sloped ground surfaces steeper than one vertical to four horizontal on which fill is to be placed shall be plowed, stepped, or broken up, as directed, in such manner that the fill material will bond with the existing surface.

### 3.5 FILLS AND EMBANKMENTS

Fills and embankments shall be constructed at the locations and to lines and grades indicated. The completed fill shall conform to the shape of the typical sections indicated. The material shall be placed in successive horizontal layers of 8 inches in loose depth for the full width of the cross section and shall be compacted as specified. Each layer shall be compacted and tested before the overlaying lift is placed. Moisture content of the fill or backfill material shall be adjusted by wetting or aerating, as required, to within plus or minus 2 percent of optimum